

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE OF PAGES 1 3	
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 12-Sep-2003		4. REQUISITION/PURCHASE REQ. NO. W16ROE-3202-8736		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, NEW YORK ATTN: CENAN-CT ROOM 1843 26 FEDERAL PLAZA (DACW51) NEW YORK NY 10278-0090		CODE DACW51		7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				<input checked="" type="checkbox"/> 9A. AMENDMENT OF SOLICITATION NO. DACW51-03-B-0021			
				<input checked="" type="checkbox"/> 9B. DATED (SEE ITEM 11) 18-Aug-2003			
				10A. MOD. OF CONTRACT/ORDER NO.			
				10B. DATED (SEE ITEM 13)			
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to provide responses to questions, make changes in the specification, and provide a cut off date for receipt of questions. "Rehabilitation of Bulkhead, Caven Point Terminal, Jersey City, NJ." The bid opening date remains UNCHANGED, 18 September 2003 at 2:00 P.M. local time. Offerors must acknowledge receipt of this amendment by the date specified in the solicitation (or as amended) by one of the following methods: on the space provided on the SF 1442, by separate letter, or telegram or, by signing block 15b below. FAILURE TO ACKNOWLEDGE AMENDMENT BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR BID IN ACCORDANCE WITH THE LATE BIDS, LATE MODIFICATIONS OF BIDS OR LATE WITHDRAWAL OF BIDS (FAR 14.304). Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 12-Sep-2003	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

REHAB OF BULKHEAD, CAVEN POINT

AMENDMENT 2

SPECIFICATIONS and PLANS

1. Add to Section 03300, Page 16, Paragraph 3.1.2 the following sentence at the end: "Reinforcing steel shall be epoxy coated and conform to "ASTM A 775/ A775M – (1996) Epoxy – Coated Reinforcement Steel Bars".
2. Section 02464, Page 2, Paragraph 2.1, Sentence 1: Delete "AZ-18" and replace with "AZ-26 or equivalent".
3. Replace plan sheets 1 through 13 with revised plan sheets 1 through 13.

The New York District has received several questions. The New York District believes that this amendment addresses these.

No additional questions will be accepted after COB on 16 September 2003.

QUESTIONS and ANSWERS

1. Are the existing ladders to be re-used?

ANSWER

The ladders will be re-used.

2. What happens to the existing gangway?

ANSWER

The existing gangway will be re-used.

3. What type of restoration is required behind the cast-in-place concrete pile cap?

ANSWER

There is no excavation beyond the pile cap. No restoration is needed behind the pile cap.

4. Can the existing lamppost be reinstalled on the new concrete pile cap?

ANSWER

The lamppost can be installed on the new concrete pile cap.

CLARIFICATIONS

There are no additional specifications for the removal and reinstallation of the existing electrical cables or switch boxes. They shall be reinstalled under the direction of Caven Point personnel.

For Plan Sheet 8 and Specification 02882: The minimum diameter of the timber piles is 12”

(End of Summary of Changes)